



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Inorganic Chemistry**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**Certificate of Analysis**

**FINAL REPORT**

**Report to: PATRICIA HAWKINS**

**Name of System:**

**TRANSYLVANIA CO ENVIRONMENTAL HEALTH**

**106 E MORGAN ST  
 BREVARD, NC 28712**

**The Cubhouse At Rosman Elementary  
 167 Rosman School Rd  
 Rosman, NC 28772**

**EIN: 566000343EH**

**Delivery: NC Courier**

**Profile: Lead - Water Investigation**

**Collection Date: 10/26/2020**

**Receiving Date: 10/27/2020**

StarLiMS ID	Field Number	Type	Sampling Point	Collection Time	Collected By	Lead (mg/L)
ES201027-0080-001	W-1	C-FD	2-comp prep sink	07:06	PH	0.016
ES201027-0080-002	W-2	C-30	2-comp prep sink	07:06	PH	<0.003

**Comment:** Kitchen tap at Cubhouse

**Report Date:** 10/29/2020

**Reported By:**

**Marc Komlos**

EPA Safe Drinking Water Action Level for Lead is 0.015 mg/L.

**Type Description**

**C-FD - Confirmation First Draw**  
**R-FD - Remediation First Draw**

**C-30 - Confirmation 30 Seconds Flush**  
**R-30 - Remediation 30 Seconds Flush**